

APPENDIX-VIII

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE

No. 108

Date : 30/04/2024

It is certified that an inspection team headed by RAMPRATAP (Assistant Engineer) Nohar from PHED inspected Angel Public School, PWD Road, Nohar on 29.04.2024 and found that Angel Public School, PWD Road, Nohar has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & campus as per the norms prescribed by the Central/State/U.T. Govt.

The above valid for a period of 31.03.2025

RTI

Signature with Seal :

Name : RAMPRATAP

Designation : A.En, PHED, Nohar

सहायक अभियंता
जन स्वा.अभि. विभाग
उपखण्ड नोहर, बजट ID-7521

To

ANGEL PUBLIC SCHOOL

PWD Road

NOHAR-335 523

Hanumangarh



Office of the Junior Chemist
Public Health Engineering Department, Rajasthan
District Laboratory, Hanumangarh

Report of the Chemical Examination of Water

136 Date: 06/05/2024

Reference :-03 - Dated : 29/04/2024

District : HANUMANGARH
Town : Nohar (M)

To,
PRINCIPAL
ANGEL PUBLIC SCHOOL PWD Road Nohar,
ANGEL PUBLIC SCHOOL PWD ROAD Nohar.

Sample No.	Gram Panchayat	Village/ Town	Habitation	Source Name	Location	Collection Date	Date of Examination	P.H.	Alkalinity	Total Hardness	Calcium	Magnesium	Chloride	Nitrate	Fluoride	T.D.S.
88		Nohar (M)		R.O. Unit	AANGEL PUBLIC SCHOOL Nohar	29/04/2024	02/05/2024	7.9	100	120	24	14.64	20	2	0.24	290

Sample not collected
by Lab.H.M.H

Note :- All Results Except pH are in mg/l.

Remarks : Water is Potable (P)/Unpotable (U)
No Lab./Tech.(chem)/2024-25/88

Junior Chemist
PHED Laboratory, District Laboratory



Office of the Junior Chemist
Public Health Engineering Department, Rajasthan
District Laboratory, Hanumangarh

Report of the Bacteriological Examination of Water

137 Date : 06/05/2024

District : HANUMANGARH


Sample Taker : Solan Mahssveri

To,
PRINCIPAL,
ANGEL PUBLIC SCHOOL PWD Road Nohar,
ANGEL PUBLIC SCHOOL PWD ROAD Nohar.

Reference No : 03, Dated : 29/04/2024
Date of Receipt : 30/04/2024
Date of Exam : 30/04/2024

Sample No.	Date & Time of Collection	Village / Town / City	Source Name	Location	Residual Chlorine (in mg/L)	Total Coli Form Organism (MPN per 100 ml)	Remark (As per T-Coli Form)	Remark (Water)
244	29/04/2024	Nohar (M)	R.O. Unit	AANGEL PUBLIC SCHOOL Nohar	0.2	Nil	Satisfactory	Potable

No.Lab./Tech.(Bact)/2024-25/244


Junior Chemist
PHED Laboratory, Hanumangarh

**Sample not collected
by Lab.H.M.H**