

APPENDIX-VIII

PERFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE

NO. 117

DATE 16-06-25

It is certified that an inspection team headed by **Mahendra Singh (Junior Engineer)** Nohar from PHED Inspected Angel Public School, PWD Road Nohar on 16-06-2025 and found that Angel Public School, PWD Road Nohar has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & campus as per the norms prescribed by the central/state/U.T. Govt.

The above valid for a Period of 16-06-2026.


कनिष्ठ अभियंता
जल स्वा. अभि. विभाग
नोहर गामीण १॥ १॥

Signature with Seal:

Name: Mahendra Singh

Designation: Junior Engineer

To
Angel Public School
PWD Road
NOHAR -335523
Hanumangarh


SECRETARY
ANGEL PUBLIC SHIKSHA SAMITI
NOHAR


Principal
Angel Public School
Affiliated with CBSE, New Delhi
Affiliation No. 1730302
PWD Road, Nohar (Raj.)



Office of the Junior Chemist
Public Health Engineering Department, Rajasthan
District Laboratory, Hanumangarh

Report of the Chemical Examination of Water

Reference :- 03 - Dated : 29/04/2024

136 Date: 06/05/2024

To,
PRINCIPAL,
ANGEL PUBLIC SCHOOL, PWD Road, Nohar,
ANGEL PUBLIC SCHOOL, PWD ROAD, Nohar.

District : HANUMANGARH
Town : Nohar (M)

Sample No.	Gram Panchayat	Village/ Town	Habitation	Source Name	Location	Collection Date	Date of Examination	pH	Alkalinity	Total Hardness	Calcium	Magnesium	Chloride	Nitrate	Fluoride	T.D.S.
88		Nohar (M)		R.O. Unit	ANGEL PUBLIC SCHOOL Nohar	29/04/2024	02/05/2024	7.9	100	120	24	14.64	20	2	0.24	290

Sample not collected
by Lab.H.M.H

Note :- All Results Except pH are in mg/l.

Remarks :- Water is Potable (P)/Unpotable (U)
Re Lab/Tech. (chems/2024-25/88)

SECRETARY
ANGEL PUBLIC SHIKSHA SAMITI
NOHAR

Junior Chemist
PHED Laboratory, District Laboratory

Principal
Angel Public School
Affiliated with CBSE, New Delhi
Affiliation No. 1730302
PWD Road, Nohar (Ra.)



Public Health Engineering Department, Rajasthan
District Laboratory, Hanumangarh

Report of the Bacteriological Examination of Water

137 Date : 06/05/2024

To,
PRINCIPAL,
ANGEL PUBLIC SCHOOL PWD Road Nohar,
ANGEL PUBLIC SCHOOL PWD ROAD Nohar.

District : HANUMANGARH

Sample Taker : Solan Mahssveri

Reference No : 03, Dated : 29/04/2024
Date of Receipt : 30/04/2024
Date of Exam : 30/04/2024

Sample No.	Date & Time of Collection	Village / Town / City	Source Name	Location	Residual Chlorine (in mg/L)	Total Coli Form Organism (MPN per 100 ml)	Remark (As per T-Coli Form)	Remark (Water)
244	29/04/2024	Nohar (M)	R.O. Unit	AANGEL PUBLIC SCHOOL Nohar	0.2	Nil	Satisfactory	Potable

No.Lab./Tech.(Bact)/2024-25/244


Junior Chemist
PHED Laboratory, Hanumangarh

Sample not collected
by Lab.H.M.H


SECRETARY
ANGEL PUBLIC SHIKSHA SAMITI
NOHAR


Principal
Angel Public School
(Affiliated with CBSE, New Delhi)
Affiliation No.1730302
PWD Road, Nohar (Raj.)